



ईनरुवा नगरपालिका
नगर कार्यपालिकाको कार्यालय
ईनरुवा, सुनसरी
कोशी प्रदेश, नेपाल

जेनेरेटर खरिद सम्बन्धी सूचना
(दोश्रो पटक प्रकाशित मिति : २०८०।११।०१ गते)

यस कार्यालयको लागि आवश्यक जेनेरेटर थान १ क्याटलग सपिड विधिबाट खरिद गर्नुपर्ने भएकोले जेनेरेटर आपूर्ति गर्न ईच्छुक उत्पादक कम्पनी वा त्यसको आधिकारीक विक्रेताले यो सूचना प्रकाशन भएको मितिले १५ (पन्द्र) दिन भित्र आपूर्ति गर्न चाहेको उत्पादन सम्बन्धी विवरण यस कार्यालयबाट उपलब्ध गराएको ढांचामा भरी यस कार्यालयको मौजुदा सूचीमा सुचिकृत हुने निवेदन सहित सिलबन्दी प्रस्ताव यस कार्यालयमा पेश गर्न हुन सार्वजनिक खरिद नियमावली, २०६४ को नियम ३१ (ख) को प्रयोजनार्थ यो सूचना प्रकाशित गरिएको छ । उक्त निवेदनसाथ देहायका कागजातहरू नोटरी पब्लिकबाट प्रमाणीत गरी पेश गर्नुपर्नेछ :-

- कम्पनी दर्ताको प्रमाणपत्र (नविकरण समेत)
- आधिकारीक विक्रेताको प्रमाणपत्र (नविकरण समेत)
- स्थायी लेखा नम्बर तथा मु.अ.कर दर्ता प्रमाणपत्र
- आ.ब. ०७९।०८० को कर चुक्ताको प्रमाणपत्र
- कालो सूचीमा नरहेको एवं कुनै कानूनी कारवाहीमा नपरेको सम्बन्धमा स्वघोषणा पत्र
- अख्तियारनामा पत्र (आवश्यकतानुसार आधिकारीक व्यक्तिले आफ्नो प्रतिनिधिलाई)
- मालसामानको आधिकारीक स्पेसिफिकेशन, गुणस्तर र सुविधा सहितको विवरण (क्याटलग वा ब्रोसर)
- अन्य आवश्यक कागजातहरू ।

अग्निप्रसाद अधिकारी
प्रमुख प्रशासकिय अधिकृत
प्रमुख प्रशासकीय अधिकृत



Inaruwa Municipality
Office of The Municipal Executive
Inaruwa, Sunsari

[Signature]
प्रमुख प्रशासकीय अधिकारी

Technical Specification for minimum 125 KVA Three Phase Water Cooled sound Proof Automatic Diesel Generator with ATS Panel

S.N	Particulars	Proposed/Offered
1	General Features	Manufacturer:
		Brand:
		Type/Model:
		Country of Origin:
2	Functional Features	Capacity: minimum 125KVA
		Power KW:
		Voltage:
		Frequency/Engine Speed:
		Rated Current (A):
		Power Factor:
		Fuel Tank Capacity: at least 100 Liter
3	Engine Parameters	Noise Level:
		Rated Power@100% load (HP):
		Cylinders:
		Aspiration:
		Displacement in liters:
		Total Lubrication System Capacity in Liter:
		Radiator Coolant Capacity in Liter:
		Fuel: Diesel
4	Fuel Consumption	Starting System:
		Cooling System:
4	Fuel Consumption	Fuel Consumption@100% of Load:
		Fuel Consumption@75% of Load:

[Signature]

[Handwritten signature]



[Handwritten signature]
10/11/2024 5:12 PM

S.N	Particulars	Proposed/Offered
5	Fuel Consumption@50% of Load:	
	Type:	
	Voltage:	
	Phase:	
	Frequency:	
	Speed:	
	Voltage Regulation:	
	Insulation Class:	
	Control Panel Parameters:	
	Protection Features Offered by Controllers:	
	Electrical:	
Standard:		
6	Power Cable: 95 sq.mm. aluminum, 4 core, Armored	
	Warranty: Minimum 2 years or more than 5500 Hours	
	A set of tools as required for general maintenance shall be supplied	
7.	Delivery, Installation and commissioning	DG (1) unit shall be delivered, installed and commissioned to Inaruwa Municipality, Office of The Municipal Executive, Inaruwa, Sunsari, Nepal

Note:

- The major items are indicated by bold and highlighted letters in the technical specifications. non-compliance of these major items will result in non-responsiveness of the bid offer.
- All the required action of local fright, unloading crane service, civil works (if required), earthing, cabling, exhaust piping, labour charge associated, inspection and commissioning charge should be on account of the supplier.

[Handwritten signature]